



December 10, 2010

BASE PRODUCTS CORPORATION
WILLIAM BONIFACIO
265 MAYVILLE AVE.
BUFFALO NY 14217

Re: Description: ALTERNATE PRODUCT REVIEW FEE
Manufacturer: BASE PRODUCTS CORPORATION
Product Name: WATER POWERED SUMP PUMP
Model Number(s): RB750, HB1000 & CB1500
Product File No: 20100389

The specifications and/or plans for this plumbing product have been reviewed and determined to be in compliance with chapters Comm 82 through 84, Wisconsin Administrative Code, and Chapters 145 and 160, Wisconsin Statutes.

The Department hereby issues an alternate approval to s. Comm 82.41 based on the Wisconsin Statutes and the Wisconsin Administrative Code. This approval is valid until the end of December 2015.

This alternate approval is contingent upon compliance with the following stipulation(s):

- This product shall be modified so that the vacuum breaker is 6" above the point of discharge. In order to be in compliance with the ASSE 1001 standard the venturi fitting shall be 6" below the vacuum breaker.

A sketch explaining this modification can be found in Attachment A.

- Additional information is included as attachment(s) to this letter; see attachment A.

The department is in no way endorsing this product or any advertising, and is not responsible for any situation which may result from its use.

Sincerely,

Jerry Thompson
Plumbing Product Reviewer
Phone: 608-266-6742
Fax: 608-267-9566
E-mail: jerry.thompson@wi.gov